

DOCUMENT 00 9111 - ADDENDUM NO. 1

DATE: 02/23/2017
FROM: Architectural Expressions, LLP
113 Illini Drive
Forsyth, IL 62535
TO: PROSPECTIVE BIDDERS
SUBJECT: ADDENDUM NO. 1 TO THE BIDDING DOCUMENTS FOR

Decatur Housing Authority
Miscellaneous Improvements at the Hartford and Lexington
CFP IL06-P012-50115/50116

This addendum forms a part of the bidding and contract documents and modifies the original bidding documents, dated February 10, 2017. Acknowledge receipt of this addendum in the space provided on the Bid Form. FAILURE TO DO SO MAY SUBJECT BIDDER TO DISQUALIFICATION.

GENERAL:

ITEM DESCRIPTION

Clarification Please note on drawings L-A601 and L-A602, Remarks Legend, R6. All balcony hand rail and fascia to be painted.


DRAWINGS:

| ITEM | DRAWING | DESCRIPTION |
|-------------|----------------|--|
| D-1 | H-A101 | ADD General Note C , to read: "Paint all exterior handrails on grade level." |
| D-2 | H-A101 | ADD General Note D , to read: "Paint all exterior mechanical louvers on the building." |
| D-3 | H-A101 | ADD Demolition General Note C , to read: "Move all furniture, equipment, and wall hangings in all areas where work has been directed. Reinstall after completion of work." |
| D-4 | H-A101 | CHANGE Keynote reference 12 in the elevator adjacent to Elevator Lobby 137 , to read: "1" . There is no work to be completed inside this elevator car. |
| D-5 | H-A601 | ADD R9 to the RMK column for Office 110, Men's Toilet 116, and Women's Toilet 117. ADD R9 in the Remarks Legend to read: "Remove vinyl wall border and patch wall to receive new painted finish." |
| D-6 | H-A601 | ADD R10 to the RMK column for Lounge 109 and Lounge 112. ADD R10 in the Remarks Legend to read: "Paint soffit and ceiling." |
| D-7 | H-A601 | ADD R11 to the RMK column for dining Room 118. ADD R11 in the Remarks Legend to read: "Paint soffit." |

| ITEM | DRAWING | DESCRIPTION |
|------|---------|--|
| D-8 | L-A101 | ADD General Note D, to read: "Paint all exterior handrails on grade level." |
| D-9 | L-A101 | ADD General Note E, to read: "Paint all exterior mechanical louvers on the building." |
| D-10 | L-A101 | ADD Demolition General Note C, to read: "Move all furniture, equipment, and wall hangings in all areas where work has been directed. Reinstall after completion of work." |

Sincerely,

ARCHITECTURAL EXPRESSIONS, LLP



JOHN E. LIGON, AIA

This addendum consists of two (2) pages and no attachments: